



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PO Box 47600 • Olympia, WA 98504-7600 • 360-407-6000

711 for Washington Relay Service • Persons with a speech disability can call 877-833-6341

September 6, 2007

Mr. Morris Malone
The Bag Lady, Inc.
11124 Valley Avenue East
Puyallup, WA, 98372

RE: Construction Entrance Plates

Dear Mr. Malone:

The Washington State Department of Ecology (Ecology) finds that the construction entrance plates can be used as a temporary erosion control mechanism. These plates must adhere to the guidelines of BMP C105 Stabilized Construction Entrance, found in Volume II of the Stormwater Management Manual for Western Washington, or Chapter 7 of the Stormwater Management Manual for Eastern Washington. The design requirements should adhere to the minimum length, width, and geotextile requirements of BMP C105. Follow manufacturer's guidelines for installation.

Contractors may use Construction Entrance Plates at project sites without seeking additional Ecology approval. However, Ecology cannot endorse this product or its manufacturer.

For more information contact: Mieke Hoppin at (360) 407-6435 or at mhop461@ecy.wa.gov.

Sincerely

Nancy Winters
Program Development Services
Water Quality Program

